

2810 Clark Avenue • St. Louis, MO 63103-2574 • (314) 531-8080 • FAX (314) 531-8085
Chemical, Metallurgical, Mechanical, Nondestructive, Environmental Testing, Analyses and Field Service.

April 5, 2005
Lab No. 05E-0379
Page 1 of 1
(Revised Report 6/19/06)

ICL PERFORMANCE PRODUCTS LP
810 East Main St.
Ontario, CA 91761

Attention: George Matousek


REPORT OF TESTS

SAMPLE ID: CONCENTRATED CLASS A FOAM FIRE SUPPRESSANT,
PHOS-CHEK WD-881, LOT# 0170-019 C, SUBMITTED 3/29/05

RESULTS: %

ANALYTE	0170-019 C	TEST METHOD
Moisture	43.7	Karl Fischer Coulometric

Identification of tested specimen provided by the client.



Steve Root, Manager
Environmental Testing

SR/nmc

